



CSIR-NORTH-EAST INSTITUTE OF SCIENCE & TECHNOLOGY
JORHAT – 785 006, ASSAM
An ISO 9001:2015 Certified Organization



NAME OF THE DIVISION BSTD	Report No.: CSIR-NEIST-Jorhat/QSP/MR/20/NEIST-SEPT Reanalysis/ 13.10.2023	
TEST REPORT OF: Bacteriological analysis of water sample	DATE 13.10.2023	PAGE 1 of 1

2. RESULT:

Sl No	Sample Identification details	Total Count/ml (CFU)	MPN Coliform /100 ml	MPN E.coli /100 ml	Remarks
1	Bacteriological test Filter water (main Pump House)	NIL	NIL	NIL	1.The supplied water contains neither Coliforms nor E. coli.

3. CONCLUSION: The sample was collected and supplied by the party.

As per IS 10500

1. No coliforms should be there in 95% of the samples.
2. There should not be any E.coli.
3. Coliforms should not be more than 10.
4. There should not be coliforms in two consecutive samples of the same source.

TEST CONDUCTED BY	CHECKED BY	APPROVED BY
 13/10/2023 Name : Babli Borah Designation: T.A	 13/10/2023 HOD, BSTD	 13/10/2023 Dr. A.M. Das Approved Authorized Signatory (Chairman, Testing Report Committee)